

# Confirmation

## LEED

On 13 November 2015, Eurofins Product Testing A/S received a sample of a construction adhesive with the product name:

### ESSVE HY

supplied by

### ESSVE Produkter AB

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, ISO 11890-1 and ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00366601\_H\_EN\_09 and 392-2015-00357601\_14).

**The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

26 September 2018



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry